

Certificate

SLA-0167/2009, Ver. 1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies

GE Sensing & Inspection Technologies

1100 Technology Park Drive
Billerica MA 01821-4111 USA

that the ultrasonic flow measurement system

PanaFlow HT

is capable for safety related applications up to SIL 2 (HFT = 0) and up to SIL 3 (HFT > 0) and meets the requirements listed in the following standards.

- IEC 61508 part 1, part 2 and part 3: 2010

The certification is based on the report
SLA-0167/2009TB-3 in the valid version.
This certificate entitles the holder to use
the pictured Safety Approved mark.

Expire date: 2017-09-21
Reference No.: G.SEB.BS.02.019.01.031


Gerhard M. Rieger
Branch manager
Augsburg, 2012-09-21

